



MODÈLE

NOTES

QUANTITÉ

DATE _____



IP44



Technical drawing of a flange. The drawing shows a top view of a circular flange with a central raised section. Dimensions are indicated: 114 (total width), 100 (inner diameter), ø79 (inner diameter of the central hole), and ø200 (outer diameter).

Plafond
Surface
Verre opalin blanc
Aucune correspondance RAL
IP44
Intérieur
705 lm

4000 K
CRI ≥ 95
L80 / 60000 h
≤ 2 SDCM (initial MacAdam)

Opal
CIE flux code: 33 60 82 64 100

phase-cut dim
220 - 240 V
système 8.3 W
Classe 1

diamètre 200 mm
hauteur 114 mm
0.55 kg


Facteur de maintenance

Temps de fonctionnement [h]	10.000	20.000	30.000	40.000	50.000
LLMF	0.97	0.93	0.9	0.86	0.82
LSF	1	1	1	1	1

MF	$LMF \times RSMF \times LLMF \times LSF$	RSMF ^a	Facteur de maintenance des parois du local
MF	Facteur de maintenance	LLMF	Facteur de maintenance du flux lumineux
LMF ^a	Facteur de maintenance du luminaire	LSF	Facteur de survie des lampes

^aSelon "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. Les valeurs doivent être déterminées par le planificateur.