



PROJECT

---

TYPE

---

NOTES


---

QUANTITY

---

DATE

---



Ring shaped suspended luminaire made from die-cast aluminium; inclusive adjustable cable suspension max. 4000mm and base in Signal Black; surface Champagne; wet painted, smooth semi glossy; silicone cover; PCB 3-step binning; phase-cut dim; light colour 2700 K; binning initial MacAdam  $\leq 3$  SDCM; CRI  $\geq 90$ ; 220 - 240 V; degree of protection IP20; Class 2; driver included; light source replaceable by Wever & Ducré or by a professional with explicit authorization; control gear replaceable by end-user;

**GENERAL**

Ceiling \_\_\_\_\_  
 Suspended \_\_\_\_\_  
 Champagne \_\_\_\_\_  
 IP20 \_\_\_\_\_  
 Interior \_\_\_\_\_  
 760 lm \_\_\_\_\_  
 CIE flux code: 23 50 78 50 100 \_\_\_\_\_

**LED**

2700 K \_\_\_\_\_  
 L80 / 100000h \_\_\_\_\_

**OPTICAL**


Opal \_\_\_\_\_

**ELECTRICAL**

phase-cut dim \_\_\_\_\_  
 220 - 240 V \_\_\_\_\_  
 system 10.7 W \_\_\_\_\_  
 Class 2 \_\_\_\_\_

**PHYSICAL**

diameter 380 mm \_\_\_\_\_  
 height 25 mm \_\_\_\_\_  
 0.59 kg \_\_\_\_\_



[271182M3] The technical data represent rated values for an ambient temperature of 25°C. The data values for the luminous flux are initially subject to a tolerance of +/- 10%, those for the electrical connected load are initially subject to a tolerance of +/- 10%, and those for the colour temperature are initially subject to a tolerance of +/- 150 K. No liability is assumed for typographical or printing errors. The general terms and conditions of Wever & Ducré BV apply.



**Maintenance Factor**

Operating Time [h]	10.000	20.000	30.000	40.000	50.000
LLMF	0.98	0.96	0.94	0.93	0.91
LSF	1	1	1	1	1

MF	$LMF \times RSMF \times LLMF \times LSF$	RSMF <sup>a</sup>	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF <sup>a</sup>	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

<sup>a</sup>According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.