




PROJECT _____

TYPE _____

NOTES _____

QUANTITY _____

DATE _____



Round shape wall surface mounted luminaire with diffuse light; aluminium base in White Matt wet painted; matt texture; aluminium shade; surface Feel Jade wet painted; matt texture; NCS S 2005 - G90Y; white opal glass handblown; with COB (Chip on Board) technology for maximum efficiency; phase-cut dim; light colour 3000 K; binning initial MacAdam ≤ 2 SDCM; CRI ≥ 90 ; CRI (Colour Rendering Index) ≥ 90 ; degree of protection IP20; Class 1; driver included; light source replaceable by Wever & Ducré or by a professional with explicit authorization; control gear replaceable by end-user;

GENERAL

Wall _____

Surface _____

Feel Jade _____

NCS S 2005 - G90Y ^a _____

IP20 _____

Interior _____

480 lm _____

CIE flux code: 15 40 69 50 100 _____

LED

3000 K _____

CRI ≥ 90 _____

L80 / 50000 h _____

initial MacAdam ≤ 2 SDCM _____

OPTICAL

Opal _____

ELECTRICAL

phase-cut dim _____

220 - 240 V _____

system 10.1 W _____

Class 1 _____


PHYSICAL

diameter 350 mm _____

height 96 mm _____

0.78 kg _____

^a Colour may deviate slightly due to production conditions.



[181484FJ5] The technical data represent rated values for an ambient temperature of 25°C. The data values for the luminous flux are initially subject to a tolerance of +/- 10%, those for the electrical connected load are initially subject to a tolerance of +/- 10%, and those for the colour temperature are initially subject to a tolerance of +/- 150 K. No liability is assumed for typographical or printing errors. The general terms and conditions of Wever & Ducré BV apply.



Maintenance Factor

Operating Time [h]	10.000	20.000	30.000	40.000	50.000
LLMF	0.96	0.92	0.88	0.85	0.81
LSF	1	1	1	1	1

MF	$LMF \times RSMF \times LLMF \times LSF$	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

^aAccording to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.